

T. R. Form No.-7 / টি. আর. ফর্ম নং-৭

( See s.1(2)(b) of T.R. 3.08 )

Challan for Deposit of money in the account of Government of West Bengal

পশ্চিমবঙ্গ সরকারের খাতে টাকা জমা দিবার চালান

1. Name of the Bank & Branch / ব্যাংকের এবং শাখার নাম : SBI Bechampore.

2. a) Name of the Treasury / ট্রেজারীর নাম : Bechampore Treasury.

b) Treasury Code / ট্রেজারীর সাতভিত্তিক কোড : M U A

3. Account Code / হিসাবখাত নং : 0 0 7 0 0 0 1 0 9 0 0 1 1 3

( 14-Digits must be filled up properly / ১৪-ঘর সঠিকভাবে অংশই পূরণ করতে হবে )

4. Detail Head of Account / হিসাবখাতের বিশদ বিভাগ :

5. a) Amount / টকা : Rs. 10000/-

b) In Words / Rupees : Ten thousand only.

6. By whom tendered-Name & Address / যে টাকা জমা দিচ্ছে তার নাম, ঠিকানা : Dali Kundu,

Secretary, Organising Committee Dali Kundu Primary Teachers Training Institute, Vill+P.O.-Kagram, P.S. Salar, Dist. Murshidabad.

7. Name / Designation & Address of the Departmental Officer on whose behalf / favour money is paid

যে বিভাগীয় আধিকারিকের হয়ে / জন্য টাকা জমা দেওয়া হচ্ছে তার নাম/পদের নাম এবং ঠিকানা :

The Director General, West Bengal Fire & Emergency Services,  
13-D Mirza Ghalib Street, Kolkata - 700016

8. a) Particulars & Authority of Deposit যে কারণে এবং ক্ষমতা অনুসারে টাকা জমা দেওয়া হচ্ছে :

b) T.V. No. & Date of A.C. Bill এ. সি. বিলের টি.ভি. নং এবং তারিখ :

Fees for Noc.  
of Educational building.

9. Accounts Officer by whom adjustable

একাল্টন অফিসার দ্বারা স্বাক্ষর করা যাবে :

Accountant General (A&B) W.B.

মহাগণনিক ( হিসাবে ও হক ), পশ্চিমবঙ্গ

Verified পরীক্ষিত :

Signature of Departmental / Treasury Officer

বিভাগীয় / ট্রেজারী আধিকারিকের স্বাক্ষর

Depositor's Signature

আমানতকারীর স্বাক্ষর

Date / তারিখ :

Treasury Receipted Challan No. ট্রেজারী গৃহীত চালান নং :

Received Payment / টাকা পাওয়া গেল

Bank Scroll Serial No. ব্যাংকের স্ক্রলের ক্রমিক নং :

Receipt by the Bank / Treasury সাক্ষর / ট্রেজারী রসিদ :

Date তারিখ :

Signature with seal of the Bank

ব্যাংকের সীলমোহরসহ এহীতার স্বাক্ষর

\*In respect of Challan relating to refund of unspent amount of A.C. Bill

এ. সি. বিলে উল্লেখিত অগ্রিমের অবশিষ্ট অর্থ ফেরত দেওয়ার চালানের জন্য



Dali Kundu Primary Teachers Training Institute  
VIII. & P.O.-Salar, Dist. Murshidabad

**GOVT. OF WEST BENGAL**  
**Office of the Divisional Fire Officer D-2 Division**  
**West Bengal Fire & Emergency Services**  
**C.R. Das Road, Berhampore, Murshidabad.**

**Memo No.** FS/D2/21/12

**Dtd.** 30.01.2012

- From :** The Divisional Fire Officer D-2 Division  
W.B. Fire & Emergency Services,  
Berhampore, Murshidabad.
- To :** Dali Kundu  
Secretary,  
Organising Committee,  
Dali Kundu Primary Teachers' Training Institute  
Vill. & P.O. Kagram, P.S. Salar, Dist. Murshidabad.
- Sub. :** Provisional N.O.C. in favour of proposed (G+1) P.T.T.I. Building  
named Dali Kundu Primary Teachers' Training Institute

There is no objection from fire service point of view to issue provisional N.O.C. in favour of Dali Kundu Primary Teachers' Training Institute, two storied building on the plot no. 12265 & 12266, Kh. No. 15204, Mouza - Talibpur, J.L. No. 107 under Talibpur Gram Panchayat, P.S. Salar, Dist. Murshidabad. Subject to fulfillment the following recommendations.

**RECOMMENDATIONS :**

- 1) The whole construction of the building shall be carried out as per approved plan drawing confirming the relevant rule of Local Panchayat Body as well as N.B.C. of India 2005.
- 2) The floor area exceeds 1601.2 sq. mts. shall be suitably compartmented by separation walls upto ceiling level having 2 hours fire resistance capacity.
- 3) The interior finish decoration of the building shall be made low flame spread materials confirming I.S. specification.
- 4) Provision of ventilation of the crown of central core duct of the building shall be provided.

(Contd. ....P/2)



*Attested*  
*to in*  
*18/2/19*  
Principal  
Dali Kundu Primary Teachers Training Institute  
Vill. & P.O.-Salar, Dist.-Murshidabad



- ✓ Arrangement shall have to be made for sealing all the vertical ducts by the materials of adequate Fire resistance capacity.

6) Parapet should be made minimum 2' 6" .

**B. OPEN SPACE & APPROACH ROAD. :**

- 1) The open space of the surrounding building shall confirming the relevant building rules as well as to permit the accessibility and maneuverability of Fire Appliances with turning facility.
- 2) The approach road shall be sufficiently strong to with stand the load of fire engine weighting to 20 mt.
- 3) The width and height of the access gates into the premises shall not be less than 4.5 mtr. & 5 mtr. Respectively by abounding the road.

**C. STAIR CASES :**

- 1) The stair case of the building shall be enclosed type, entire construction shall be made brick/RCC type having fire resistance not less than 4 hrs.
- 2) The stair case of the building shall have permanent vents at the top and openable sashes at each floor level in the external wall of the building.
- 3) All the stair cases shall be extended up to tarace of the building and shall be negotiable to each other without entering into any room.
- 4) Another stair case should be made at the north side of the building for the safety of the students and other. Stair case shall be made as per N.B.C. (Part IV) of India.
- 5) For existing building a certificate obtain from the appropriate authority regarding constructional safety point of view as well as clearance certificate for electrical installation, fitting if any.
- 6) Under ground reservoir having capacity 50,000 ltrs. Always kept full and free from all obstruction.
- 7) Provision of standard Hose Real Hose supplied water from overhead reservoir (capacity 20,000 ltrs.) through booster pump will have to made in all the floor of the building to satisfying the code of I.S. specification 3844 - 1989. The system will be adopted in each floor by installing minimum 4 nos. Hose Real Hose positively. By the constructional method for fire prevention & protection.

(Contd. ....P/3)



*Attested*  
Principal  
18/12/19  
Dali Kundu Primary Teachers Training Institute  
Vill. & P.O.-Salar, Dist.-Murshidabad

First Aid Fire Fighting System. : First Aid Fire Fighting Arrangement in the style of placing suitable type fire extinguisher CO2 4.5 kg. X 4, D.C.P. 5 kg. X 10, Water CO2 9 ltrs. X 6, Fire bucket etc. in all floor in visible location of the building shall be installed in accordance with I.S. 2190 - 1992.

- 9) **General Recommendation** : All the extinguisher should be tested at least once in a year by an authorise agency and certificate shall be pasted on the body of the extinguisher.
- 10) Fire licence shall have obtained in case of storing and processing with L.P.G. & other highly combustible article if any.
- 11) No cooking arrangement should be made in the college building.
- 12) Electrical main meter & main switch should be kept safe distance from the main building with proper protection by CO2 / DCP fire extinguisher.
- 13) Exit & Entry must be marked with red lamp.
- 14) Mock exercise and evacuation drill must performed with regular interval.
- 15) Good house keeping must be maintained.
- 16) All the teachers and non-teaching staff should have knowledge to operate fire fighting equipments and awareness of fire.
- 17) After completion of the all fire safety installation of the building a letter of intimation must be submitted to this office for final inspection to issue the final N.O.C. of the building.
- 18) Violation of any recommendation mention above legal action will be taken as per fire service Act. 1950 (upto date amendment) and the provisional N.O.C. shall be treated as cancel.

Attested

*[Signature]*  
Principal



Dak Kundu Primary Teachers Training Institute  
VII. & P.O.-Salar, Dist.-Murshidabad

*[Signature]* 30/01/2012  
Divisional Fire Officer,  
D-2 Division  
W.B. Fire & Emergency Services,  
Berhampore, Murshidabd.

Divisional Fire Officer  
D-2 Division - Berhampore  
West Bengal Fire & Emergency Services



Government of W.B  
Department of Fire Services  
(For building of all categories)  
13 D, Mirza Ghalib Street  
Kolkata-16

Memo No. FS/D2/18/12

Dated of: 25/01/2012

To

Dali Kundu  
Secretary - Organising Committee, Dali Kundu P.T.T.I  
Vill + P.O. Kargram P.S. Salar, Dist. Murshidabad  
S.O.B. Demand Notice under Section 11C of WBFS Act 1950 as amended for  
issue of Provisional N.O.C for the Premises No. Plot No-12265 & 12266 Kh.No-15204  
Mouza Talib PM, JL-NO-107, Under Talib PM G.P P.S. Salar  
Dist. Murshidabad

Dear sir/Madam,

With reference to the building application submitted in respect to the above proposed this is to inform you that the building permit along with the sanctioned plan will be issue subject to the payment of Fee amounting Rs. 10000/-. You are hereby requested to remit the above amount immediately from this received of this notice.

Total Floor Area (In sq.mtr): 800.6 sqm 1601.2 sqm  
Ground Floor Area(In sq.mtr): 1601.2 sqm - 800.6 sqm  
Primary Use Group: Educational Institute  
Total Additional Floor Area: \_\_\_\_\_  
Abutting Road Width: 12 feet  
Amount in words: Ten Thousand only

**Mode of Payment :**

Treasury challan drawn in favour of - " 0070-Other Administrative Services -00-109- Fire Protection and Control- 001 - fees under the West Bengal Fire Services Act -13- License Fees " (A.C. Code :0070-00-109-001-13)- to be deposited in Treasury/RBI.

The Treasury/RBI challan receipt (In Original) should be submitted in this Office. On receipt, of the same provisional N.O.C, Will be issued.

Your's Faithfully,

Attested

18/12/19  
Principal



Dali Kundu Primary Teachers Training Institute  
Vill. & P.O.-Salar, Dist.-Murshidabad

Ref: FS/D2/18/12

hep  
Director,

West Bengal Fire & Emergency Services.